



ADMINISTRATIVE RULES OF MONTANA



37.106.1925 MENTAL HEALTH CENTER: COMPLIANCE WITH BUILDING AND FIRE CODES, FIRE EXTINGUISHERS, SMOKE DETECTORS, AND MAINTENANCE

- (1) Each mental health center shall ensure that its facilities, buildings, and homes:
 - (a) meet all applicable state and local building and fire codes;
 - (b) have a workable portable fire extinguisher on each floor, with a minimum rating of 2 A10BC. Extinguishers must be readily accessible at all times; and
 - (c) have a properly maintained and regularly tested smoke detector, approved by a recognized testing laboratory, on each floor. Building exits must be unobstructed and clearly marked.
- (2) Each mental health center shall ensure its facilities, buildings, homes, equipment, and grounds are clean and maintained in good repair at all times for the safety and well being of its clients, staff, and visitors.

Authorizing statute(s): 50-5-103, MCA

Implementing statute(s): 50-5-103, 50-5-204, MCA

History: NEW, 1998 MAR p. 539, Eff. 2/27/98; TRANS, from DHES, 2002 MAR p. 916.