




ADMINISTRATIVE RULES OF MONTANA



38.5.8402 APPLICABILITY

- (1) The interconnection procedures set forth in this subchapter apply to applicants proposing to install and interconnect a small generator facility to an EDC's system that satisfies the following criteria:
 - (a) The small generator facility must be sited on the utility customer's premises;
 - (b) The customer installing the small generator facility must be in good standing with the utility;
 - (c) The proposed small generator facility's point of interconnection may not be on a transmission line;
 - (d) The power produced from the small generator facility must be contained on the EDS and not flow onto the transmission system; and
 - (e) The power exported by an interconnection customer can only be sold to the EDC.

Authorizing statute(s): 69-3-103, MCA

Implementing statute(s): 69-3-102, MCA

History: NEW, 2010 MAR p. 1801, Eff. 8/13/10.