



ADMINISTRATIVE RULES OF MONTANA



36.21.669 PLUMBNESS AND ALIGNMENT TEST

- (1) The completed well shall be sufficiently plumb and straight so that there will be no interference with installation, alignment, operation or future removal of the permanent pump.

Authorizing statute(s): 37-43-202(3), MCA

Implementing statute(s): 37-43-202(3), MCA

History: NEW, 1986 MAR p. 1699, Eff. 10/17/86.