



ADMINISTRATIVE RULES OF MONTANA



36.22.1102 FIRE WALLS REQUIRED

When it is deemed necessary by the board to protect life, health, or property, the board may require any lease tanks or oil storage tanks to be surrounded by an earthen dike which shall have a capacity of 1 1/2 times the capacity of the tank or tanks it surrounds and which dike shall be continually maintained; and the reservoir within shall be kept free from vegetation, water, or oil.

Authorizing statute(s): Sec. 82-11-111, MCA

Implementing statute(s): Sec. 82-11-123 and Sec. 82-11-124, MCA

History: Eff. 12/31/72.